

Attestation

Italian CAM

On the 19th of April 2023, Eurofins Product Testing A/S received a sample of a sandwich panel with the product name:

Setto Acustico CG

supplied by


Tecnasfalti Srl

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 183 del 6 agosto 2022. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2023-00166001_A_EN).

Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m³.
- Formaldehyde after 28 days was below the limit of 60 µg/m³.
- All other parameters were below their respective limit values after 28 days.

29 June 2023



Liva Kjær Hansen
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager